



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
RURAL WATER SUPPLY & SANITATION SUB-DIVISION LABORATORY
Sharada Colony, Before GLBC, Jamkhandi-587301
e-mail:rdwsd.wqmsspjamkhandilab@gmail.com

TEST REPORT

Location : Vidyabhavan International Public school Habitation: Siddapur Village : Siddapur G P : Siddapur Taluka : Jamkhandi District : Bagalkot			Report date : 06-04-2024	Report Number : JKDAPR001	Reference : Sample receipt Form
Sample Particulars: RO			Sample receipt date : 05-04-2024	Sample code : JKD2024APR0001	Date of Sample Collection : 05-04-2024
			Analysis start date : 06-04-2024	Analysis completion date : 06-04-2024	Sample collection protocol : APHA Method
			Sample quantity : 1000ml		
Sl.No	Test	Results	Acceptable Limit is 10500 :2012	Permissible Limit is 10500 :2012 RA:2018	Protocol
1	pH Value @Temp 25±2°C	7.75	6.5-8.5	No Relaxation	IS 3025 (part-11) :2022
2	Specific Conductance, µS/cm @Temp 25±2°C	52	-	-	IS 3025 (part-14) :2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (part-5&6) :2018
4	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (part-8) :2023
5	Colour, Hazen Units	<5	5	15	IS 3025 (part-4) :2021
6	Turbidity ,NTU	.01	1	5	IS 3025 (part-10) :2023
7	Total Dissolved Solids ,@180mg/l	31.7	500	2000	IS 3025 (part-16) :2023
8	Alkalinity as CaCO ₃ ,mg/l	16.53	200	600	IS 3025 (part-23) :2023
9	Total hardness as CaCO ₃ ,mg/l	20.10	200	600	IS 3025 (part-21) :2009
10	Calcium as Ca,mg/l	4.83	75	200	IS 3025 (part-40) :1991
11	Magnesium as Mg,mg/l	1.95	30	100	IS 3025 (part-46) :2023
12	Chloride as Cl,mg/l	9.88	250	1000	IS 3025 (part-32) :1988
13	Sulphate as SO ₄ ,mg/l	3	200	400	IS 3025 (part-24, Sec.1) :2022 Method.a
14	Fluoride as F ,mg/l	0.45	1	1.5	APHA 23rd Edition
15	Nitrate as NO ₃ ,mg/l	1.30	45	No Relaxation	APHA 23rd Edition
16	Iron as Fe ,mg/l	0.03	1	No Relaxation	IS 3025 (part-53) :2003 Method.a
Remarks: The given sample conforms to the Acceptable limits of IS:10500:2012 RA2018 Drinking water specification for above tested physical & Chemical parameters only. <i>Se</i>					

RDWSD/WQMSP/TeR/1

Santosh S Rebnal
Analysed By: **Santosh S Rebnal**
Analyst
Sub-Division Laboratory
RDW & S Sub-Division,
JAMKHANDI - 587301

J P Shetty
Authorised Signatory: **J P Shetty**
Assistant Executive Engineer
Assistant Executive Engineer
R.D.W.S.S.
Sub-Division, JAMKHANDI.

- Note:
- 1) The above results, relates only to the sample tested.
 - 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
 - 3) The Traceability : Traceability of measurements is established using CRM's traceable to National/International standards.
 - 4) Samples will be discarded after 15 days from the date of report generation.
 - 5) Decision rule is applicable as per the procedure mentioned in the RDWSD/WQMSP/DR-01.
 - 6) Sample brought by the customer

PERFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 016

Date: 26/4/2024

It is called that an inspection team headed by Taluka Health Officer and Sr. Health Inspector Jamkhandi from Health Department Jamkhandi inspected the VIDYABHAVAN INTERNATIONAL PUBLIC SCHOOL, HULYAL CROSS, JAMKHANDI on 15.03.2024 & found that the VIDYABHAVAN INTERNATIONAL PUBLIC SCHOOL has safe drinking water facilities for the students and members of staff of the institution & is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the central/state/U.T. Govt.

The above is valid for a period of 5 years.

Signature with seal: 

TALUKA HEALTH OFFICER
JAMKHANDI, Dist. Bagalkot.

Name

Dr GAIBUSAB GALAGALI

Designation

TALUKA HEALTH OFFICER
JAMKHANDI, Dist. Bagalkot.

To
The Secretary,
Shri Gurudev Ranade Memorial Education Society ® Jamkhandi
Hulyal Cross, Jamkhandi.